

Created Date	Site ID	Site Name	Water Response	Waste Response
26/01/2022	53650	EW2: West Eynsham Strategic Development Area - ADOPTED	<p>The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment. The developer can request information on network infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development.</p>	<p>Infrastructure at the wastewater treatment works is operating close to capacity. It is recommended that the developer liaise with Thames Water at the earliest opportunity to determine the magnitude of spare capacity in the system and a suitable connection point. As set out in the Planning Policy Guidance, early contact with statutory undertakers (such as Thames Water) is recommended. The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>
26/01/2022	53647	Land North Of A40 A40 Section From Bernard Gate To Eynsham Roundabout (Pending)	<p>The scale of development/s in this catchment is likely to require upgrades of the water supply network infrastructure. It is recommended that the Developer and the Local Planning Authority liaise with Thames Water at the earliest opportunity to agree a housing phasing plan. Failure to liaise with Thames Water will increase the risk of planning conditions being sought at the application stage to control the phasing of development in order to ensure that any necessary infrastructure upgrades are delivered ahead of the occupation of development. The housing phasing plan should determine what phasing may be required to ensure development does not outpace delivery of essential network upgrades to accommodate future development/s in this catchment. The developer can request information on network infrastructure by visiting the Thames Water website https://developers.thameswater.co.uk/Developing-a-large-site/Planning-your-development.</p>	<p>Infrastructure at the wastewater treatment works in this area is unlikely to be able to support the demand anticipated from this development. Significant infrastructure upgrades are likely to be required to ensure sufficient treatment capacity is available to serve this development. Thames Water would welcome the opportunity to work closely with the Local Planning Authority and the developer to better understand and effectively plan for the sewage treatment infrastructure needs required to serve this development. It is important not to under estimate the time required to deliver necessary infrastructure. For example: Sewage Treatment Works upgrades can take 18 months to 3 years to design and build. Implementing new technologies and the construction of a major treatment works extension or new treatment works could take up to ten years The wastewater network capacity in this area may be unable to support the demand anticipated from this development. Local upgrades to the existing drainage infrastructure may be required to ensure sufficient capacity is brought forward ahead of the development. Where there is a potential wastewater network capacity constraint, the developer should liaise with Thames Water to determine whether a detailed drainage strategy informing what infrastructure is required, where, when and how it will be delivered is required. The detailed drainage strategy should be submitted with the planning application</p>